



INSTRUCTIONS:

- LCBus wire from POWER PANEL to fixture.
- Cat5 from PDM to POWER PANEL.
- If multiple CV fixtures, run LCBus between fixtures.
- ID field wires at both ends.

APPLIES TO:

- High power Constant Voltage fixtures, Constant
- Voltage LED strips, chandeliers, and fixtures
- requiring MORE than 1.20 Amps.